

FIRE AUDIT REPORT

Year: 2023-24

Report No. –Fire Audit/2023/0050

**TO,
GOVT DEGREE COLLEGE
SHAHPURA DINDORI
(M.P) INDIA.**

**Sub :-Submission of fire audit report of building name – Govt. Degree College
Add:- Shahpura Distt. Dindori (M.P) India**

Sir ,

I **Sourabh Sharma** B.E Fire& Safety, Authorized Fire have inspected your building /premises on (dated) **15/09/2023 checked** all Fire Equipment /Installations and have completed the Fire Audit of said building /premises for which **Fire NOC No.** issued by Fire Authority.

Details of fire system installed areas below:

Sr No	Particular	Available/ Installed or not installed as per requirement(give Comments)	Comments for working of system (attached details , ifneeded)
1	Access	Available	From front Road side
2	Wet Riser	Not Required	
3	Down Comer	Not Required	
4	Hose Reel	Not Available	Need to be installed at each floor
5	Automatic sprinkler system	Not Required	
6	Yard Hydrant	Not Required	
7	Underground Tank with draw off connection	Not required	
8	Terrace Tanks	Available - 03 nos Capacity 1000 Ltr. Per tank	Separate 10,000 Liter water tank need to be provided
9	Fire Pump	Not Required	
10	Terrace Pump	Not Available	Need to be Provided @ 450 LPM Pump in each Building
11	First Aid Fire Fighting Appliances	Available Fire Extinguisher ABC Type 4KG TOTAL - 04 Nos.	Need to be provided of 4.5 KG CO2 Fire Extinguisher at each floor & ABC Fire extinguisher increase at each floor
12	Pressurized System	Not Required	Natural ventilated
13	Auto Detection System	Not Required	

MP FIRE ENGINEER & CONSULTANT

AFFILIATED FIRE CONSULTANT BY M.P. GOV. UAD DEPARTMENT

ADD:- 1257-D SECTOR SUDAMA NAGAR INDORE

MOB:- 7999525602, 9098398048

14	Manual operated Electrical Fire Alarm System	Not Required	Need to be Provided
15	P. A System with talk Back Facility	Not Required	
16	Emergency Light	Available	Provided by DG Set
17	Auto D.G Set	Available	12 KVA Provided
18	Illuminated Exit Sign	Not Available	Exit Signages need to be Provided
19	Mean of Escape	Available	01nos Staircase & 01NOS EXIT Door Provided
20	Compartmentation	Not Required	
21	MCB/ELCB/RCCB/MCCB	Available	MCB are Installed at electric panel
22	Firemen Switch in Lift	Lift Not Available	
23	Hose Boxes with Delivery Hose and Branch	Not Required	
24	Refuse Area	Not Required	
25	Any other Installation	-	

It is observed that some fire installation is missing at the site it should be installed as per the National Building Code- 2016

Date: 15/09/2023


SOURABH SHARMA
Fire Technology & Safety Engineer
Enroll No.: 0908FT091052
Mob.: 7999525602

SOURABH SHARMA
FIRE & SAFETY ENGINEER
LICENCE. NO. 13
INDORE (M.P.)

Building details :-

1. Building occupancy – Educational Building
2. Total Floors – GROUND + FIRST FLOOR
3. Building Height – 07 Mtrs.
4. Total Buildup Area – 2098.24 SQM
5. Total plot area – 10.23 Acre

OBSERVATIONS :-

1. Danger sign boards to be displayed at all Electric panels
2. Unwanted solid flammable materials to be remove from building

NOTE :- ALL FIRE FIGHTING INSTALLATIONS SHALL BE DONE AS PER NATIONAL BUILDING CODE 2016- PART -IV TABLE NO. -07 - EDUCATIONAL BUILDING (B) – 1) LESS THAN 15 MTR. IN HEIGHT - i)